

LINDAB s.r.o.
Na hůrce 1081/6
161 00 Praha 6
Czech Republic

Air tightness test of a circular duct system according to standard EN 12237:2003

(2 appendices)

Assignment

An air tightness test on a DIRECT VENT circular ventilation duct system was carried out by request of Lindab s.r.o.

Test object

A DIRECT VENT circular duct system consisting of:

- 1 pc. duct 3.0 meter, Ø 1250 mm (0.9*)
- 2 pcs. duct 1.5 meter, Ø 1250 mm (0.9*)
- 2 pcs. duct 1.5 meter, Ø 630 mm (0.7*)
- 1 pc. duct 3.0 meter, Ø 500 mm (0.7*)
- 2 pcs. duct 1.5 meter, Ø 500 mm (0.7*)
- 2 pcs. duct 3.0 meter, Ø 250 mm (0.5*)
- 2 pcs. duct 1.5 meter, Ø 160 mm (0.5*)
- 1 pc. duct 3.0 meter, Ø 80 mm (0.45*)
- 1 pc. reduction Ø 1250 mm → Ø 630 mm (0.9*)
- 1 pc. reduction Ø 630 mm → Ø 500 mm (0.7*)
- 1 pc. reduction Ø 630 mm → Ø 250 mm (0.7*)
- 1 pc. reduction Ø 250 mm → Ø 160 mm (0.5*)
- 1 pc. reduction Ø 160 mm → Ø 80 mm (0.7*)
- 1 pc. reduction Ø 100 mm → Ø 80 mm (0.5*)
- 1 pc. T-piece, Ø 630 mm → Ø 630 mm (0.7*)
- 1 pc. bend 90° Ø 250 mm (0.5*)
- 1 pc. silencer, connection Ø 250 mm
- 1 pc. damper, connection Ø 160 mm (0.5*)
- 1 pc. plug end Ø 1250 mm (0.9*)
- 1 pc. plug end Ø 500 mm (0.6*)
- 1 pc. female coupling Ø 1250 mm (1.25*)
- 3 pcs. male coupling Ø 1250 mm (0.9*)
- 1 pc. male coupling Ø 630 mm (0.7*)
- 2 pcs. male coupling Ø 500 mm (0.6*)

* sheet thickness in [mm] according to manufacturer's material specification

Ducts and fittings were made of galvanized steel. Sheet thickness was checked on randomly selected ducts and fittings and corresponded with values stated in the manufacturer's material

RISE Research Institutes of Sweden AB

Postal address
Box 857
501 15 BORÅS
SWEDENOffice location
Industrigatan 4
504 62 Borås
SWEDENPhone / Fax / E-mail
+46 10-516 50 00
+46 33 13 19 79
info@ri.se

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

Accred. No. 1002
Testing
ISO/IEC 17025

specification. Measured values were within tolerance levels according to EN 10143:2006. For photos of the duct system, see appendix 1.

Place and date of test

The test was performed by RISE on February 01, 2023, on a duct system assembled at the company's premises in Grevie, Sweden.

Test procedure

The test was carried out according to standard EN 12237:2003 "Ventilation for buildings – Ductwork – Strength and leakage of circular sheet metal ducts". The duct system was connected to a speed-controlled fan and an air flow meter to measure the air leakage.

Results

The reported values have been corrected to an air density of 1.2 kg/m³. The test was conducted at an atmospheric pressure of 987 hPa and an ambient temperature of 19°C. The system was pressurized about 5 minutes at every measurement point before the air leakage was measured.

The tested circular system had a total surface area (A) of 57.36 m² and a total joint length (L) of 59.16 m. This resulted in a ratio L/A = 1.03 m⁻¹.

The results only applies for the tested system.

Air leakage test

The measured and calculated values for pressure and air leakage factors are presented in tables 1-2 and in the diagram in appendix 2.

Table 1. Results for circular duct system at static positive pressure.

Static positive pressure Pa	Measured leakage factor l/s/m ²	Demand acc. to class B l/s/m ²	Demand acc. to class C l/s/m ²	Demand acc. to class D l/s/m ²
118	0.002	0.20	0.067	0.022
421	0.005	0.457	0.152	0.051
759	0.008	0.671	0.224	0.075
1045	0.010	0.826	0.275	0.092
1512	0.013	1.049	0.350	0.117
2013	0.016	1.264	0.421	0.140

Table 2. Results for circular duct system at static negative pressure.

Static negative pressure Pa	Measured leakage factor l/s/m ²	Demand acc. to class B l/s/m ²	Demand acc. to class C l/s/m ²	Demand acc. to class D l/s/m ²
126	0.002	0.208	0.069	0.023
206	0.003	0.287	0.096	0.032
313	0.004	0.377	0.126	0.042
397	0.005	0.440	0.147	0.049
607	0.007	0.580	0.193	0.064
752	0.008	0.667	0.222	0.074

Strength

No deformation of the duct system was observed during the test.

At the actual test the system achieved air tightness class D and strength requirements according to standard EN 12237:2003.

When comparing test results with requirements in the standard, the following decision rule has been applied: Measured values are evaluated without regard to measurement uncertainty

Estimated measurement uncertainty

Temperature $\pm 1^\circ\text{C}$	Atmospheric pressure $\pm 1\text{ hPa}$
Air flow $\pm 4\%$ of actual flow	Area $\pm 2\%$
Static pressure $\pm 1\%$ of actual pressure	Leakage factor $\pm 5\%$

The uncertainty has been calculated according to EA-4/16 with a coverage factor $k = 2$.

Measuring equipment

Temperature meter, Testo 108	Inventory number KWP09899-01
Manometer, Testo 510	Inventory number BX81272
Manometer, Testo 510	Inventory number BX81273
Barometric Pressure Meter, Testo 511	Inventory number BX81271
Air flow meter, nozzles 4 to 25 mm	Inventory number BX81487
Digital Caliper Gauge, Mitutoyo 209-918	Inventory number BX81494

RISE Research Institutes of Sweden AB Department Energy and Resources - Buildings and energy

Performed by



Ingmar Schüßler

Examined by





Svein Ruud


Appendices

1. Photos of the tested duct system.
2. Diagram: Leakage factor [l/s/m^2] as a function of static pressure [Pa].

Appendix 1



Appendix 2



Verification

Transaction 09222115557491314021

Document

Test_report_2023_1188883-01A

Main document

5 pages

Initiated on 2023-04-21 13:53:39 CEST (+0200) by Ingmar Schüssler (IS)

Finalised on 2023-04-24 15:00:01 CEST (+0200)

Signing parties

Ingmar Schüssler (IS)

RISE Research Institutes of Sweden AB

Company reg. no. 556464-6874

ingmar.schuessler@ri.se

+46 10 516 59 15

Ingmar Schüssler

Signed 2023-04-24 15:00:01 CEST (+0200)

Svein Ruud (SR)

RISE Research Institutes of Sweden AB

svein.ruud@ri.se

+46705165666

Svein M. Ruud

Signed 2023-04-24 12:42:43 CEST (+0200)

This verification was issued by Scrive. Information in italics has been safely verified by Scrive. For more information/evidence about this document see the concealed attachments. Use a PDF-reader such as Adobe Reader that can show concealed attachments to view the attachments. Please observe that if the document is printed, the integrity of such printed copy cannot be verified as per the below and that a basic print-out lacks the contents of the concealed attachments. The digital signature (electronic seal) ensures that the integrity of this document, including the concealed attachments, can be proven mathematically and independently of Scrive. For your convenience Scrive also provides a service that enables you to automatically verify the document's integrity at: <https://scrive.com/verify>

